

NASA CR-172,153

NASA Contractor Report 172153

NASA-CR-172153
19830021894

CHARACTERISTICS OF THE TRANSMISSION LOSS
APPARATUS AT NASA LANGLEY RESEARCH CENTER

Ferdinand W. Grosveld

THE BIONETICS CORPORATION
Hampton, Virginia 23666

Contract NAS1-16978
June 1983

LIBRARY COPY

JUL 19 1983

LANGLEY RESEARCH CENTER
LIBRARY, NASA
HAMPTON, VIRGINIA



National Aeronautics and
Space Administration

Langley Research Center
Hampton, Virginia 23665

NF02029

CONTENTS

| | |
|---|----|
| SUMMARY | 1 |
| INTRODUCTION | 1 |
| SYMBOLS | 2 |
| DESCRIPTION OF TRANSMISSION LOSS APPARATUS | 4 |
| METHODOLOGY FOR NOISE TRANSMISSION LOSS MEASUREMENTS | 11 |
| COMPARISON OF THE CHARACTERISTICS OF THE TRANSMISSION LOSS APPARATUS WITH ASTM AND ISO STANDARDS | 17 |
| Sound Diffusivity | 18 |
| Room Dimensions | 21 |
| Flanking Transmission | 22 |
| Ambient Noise Levels | 23 |
| Room Absorption | 23 |
| Microphone Location and Distance to Boundaries | 25 |
| Validated Frequency Region | 26 |
| CONCLUDING REMARKS | 27 |
| REFERENCES | 31 |
| APPENDIX A | 34 |
| APPENDIX B | 39 |

SUMMARY

A description of the Transmission Loss Apparatus at NASA Langley Research Center, which is specifically designed to accommodate general aviation type aircraft structures, is presented. The measurement methodology, referred to as the "Plate Reference Method", is discussed and compared with the classical method as described in the Standard of the American Society for Testing and Materials. This measurement procedure enables reliable and accurate noise transmission loss measurements down to the 50 Hz one-third octave band. The transmission loss characteristics of additional acoustical treatments, applied to the basic structure, can be established by inclusion of appropriate absorption corrections for the treatment.

INTRODUCTION

Interior noise levels in light, propeller driven general aviation aircraft are generally high and annoying, despite the use of acoustical treatments (Refs. 1-5). The degree of interior noise depends largely upon aerodynamic generated sound transmitted through the sidewall fuselage and the radiation of structural born induced sound into the aircraft cabin. Highest excitation levels are found at the propeller blade passage frequency and its harmonics which occur typically at frequencies of 70 Hz or

higher for cruise conditions of this type of aircraft. Reference 6 shows that the effectiveness of acoustic treatment is minimal for these low frequencies. This resulted in a need to expand knowledge of methods to control aircraft interior noise by establishing the noise transmission loss characteristics of light aircraft structures and acoustical treatments. To include the fundamental blade passage frequencies and their harmonics of turbo-prop and propfan driven aircraft a frequency region of interest is defined from 50 Hz to 8000 Hz. The purpose of this report is to present the characteristics of the NASA Langley Research Center Transmission Loss Apparatus which is located in the Aircraft Noise Reduction Laboratory, along with the measurement methodology which will be compared with the appropriate standards.

SYMBOLS

| | |
|----------|--|
| A | absorption area of the receiving room |
| ASTM | American Society for Testing and Materials |
| A_{eq} | equivalent absorption area |
| a, b | test panel dimensions |
| B&K | Brueel and Kjaer |
| C_w | Waterhouse correction term |
| c | speed of sound |
| D | flexural rigidity |
| d | distance |

E Young's modulus
 f frequency
 f_c critical frequency
 f_{ss} fundamental resonance frequency for simply supported boundaries
 HP Hewlett Packard
 ISO International Standards Organization
 k number of sound source positions
 L total length of all room edges
 L_b background noise level
 L_i space averaged sound pressure level
 L_m arithmetic mean of sound pressure levels
 L_s adjusted signal level
 L_{sb} signal and background level combined
 M dimensionless mass coefficient
 m, n panel mode numbers
 N number of acoustic room modes
 $NASA$ National Aeronautics & Space Administration
 NR noise reduction
 NR_{ref} noise reduction for reference panel
 n_d modal density of test panel
 R transmission loss according to mass law
 R_{ref} mass law transmission loss of reference panel
 S sound exposed area of test panel
 SPL sound pressure level

| | |
|----------------|--------------------------------------|
| S_t | total area of all room walls |
| s | standard deviation |
| T | reverberation time |
| TL | transmission loss of test panel |
| t | thickness |
| V | room volume |
| $\bar{\alpha}$ | average absorption coefficient |
| λ | wavelength |
| ν | Poisson's ratio |
| ρ | air density in test rooms |
| ρ_s | mass per unit area of the test panel |

DESCRIPTION OF TRANSMISSION LOSS APPARATUS

To experimentally establish the noise transmission loss characteristics of the test structure, the aircraft panel is mounted as a partition between two adjacent reverberant rooms which are designated source room and receiving room. The transmission loss apparatus has been modified since its design was first reported in Reference 7. A plan view of the modified apparatus is depicted in figure 1. In the source room, which measures 3.35 m by 3.66 m by 3.94 m, a random sound field is produced by two floor standing reference sound power sources. These calibrated units consist essentially of a centrifugal driven fan featuring very well defined operating characteristics and long term stability over a frequency range from 100 Hz to 10 k Hz. In this range the sound is broadband in character and the acoustic output power is greater than




Figure 1. - Schematic of noise transmission loss apparatus

70 dB in any one-third octave frequency band. Sound from the source room is transmitted into the 4.47 m by 3.36 m by 2.90 m receiving room only by way of the test panel which has a sound exposed area of 1.15 m by 1.46 m. The test specimen is accommodated by a steel and rubber mounting frame, which is designed for minimum acoustical and structural flanking (Ref. 7). Boundary conditions are defined by the 54 bolt-nut combinations evenly spaced along the edges of the test structure. Four steel bars provide an even distribution of the applied clamping forces.

A space and time average of the sound pressure levels in each of the rooms is accomplished by means of a windscreen covered 1/2 inch microphone mounted at the end of a .91 m long rotating boom which has a rotational speed of 16^{-1} revolutions per second. The microphones complete two full rotations during the 32 seconds linear time averaging analysis which is performed by a digital one-third octave band frequency analyzer. The microphone signal coming from the receiving room is amplified by a gain of 40 dB to ensure adequate analyzer input levels. Figure 2 shows an aircraft test panel mounted in the apparatus as viewed from the source room. Part of the microphone boom and the windscreen covered microphone are visible in the foreground. The same test panel, covered with various layers of treatment, viewed from the receiving room is depicted in figure 3.

The data acquisition system is automated by the inclusion of




Figure 2. - Aircraft test panel structure viewed from the source room.




Figure 3. - Aircraft test panel structure showing different layers of acoustical treatment (View from the receiving room).

a microcomputer, a relay actuator and several remote relays to control the sound sources, amplifiers, power supplies and rotating booms (figure 4). The microprocessor manipulates the experimental data from source and receiving rooms, applies corrections, stores applicable data in flexible disc memory and finally presents noise transmission loss data in tabular and graphical form. The interactive computer program used for this purpose is written in BASIC and a flowchart is presented in Appendix A. A sample output for the transmission loss of an aircraft test panel with different treatment layers is given in Appendix B. Table 1 identifies the electronic equipment used in the transmission loss apparatus.

TABLE 1. - IDENTIFICATION OF ELECTRONIC EQUIPMENT USED IN TRANSMISSION LOSS MEASUREMENTS

| | Source Room | Receiving Room |
|--|--------------|----------------|
| Reference sound power source | B&K 4204 (2) | |
| Microphone cartridge | B&K 4165 | B&K 4165 |
| Microphone preamplifier | B&K 2619 | B&K 2619 |
| Microphone power supply/ conditioner | B&K 2801 | B&K 226/228 |
| Remote relay | (2) | (2) |
| One-third octave band frequency analyzer | | B&K 2131 |
| Relay actuator | | HP 59306 A |
| Desk top computer | | HP 9845 B |
| Flexible disc memory | | HP 9895 A |
| X-Y Plotter | | HP 9872 T |




Figure 4. - General arrangement of electronic equipment

METHODOLOGY FOR NOISE TRANSMISSION LOSS MEASUREMENTS

Noise reduction is defined as the difference between the measured averaged sound pressure levels in the source and receiving rooms. These measured sound pressure levels are influenced by the transmission loss characteristics of the test specimen as well as the acoustic environment of the rooms. The Standard Method for Laboratory Measurement of Airborne Sound Transmission Loss of Building Partitions (Ref. 8), often referred to as the Classical Method, assumes that the sound pressure levels are measured in a diffuse field in both source and receiving rooms. This method corrects for the room characteristics in the form of the absorption area A of the receiving room yielding the noise transmission loss TL of the test specimen:

$$TL = NR + 10 \log \left(\frac{S}{A} \right) \quad (1)$$

where S is the area of the test specimen common to both rooms. The absorption area may be obtained from Sabine's formula (Ref. 9):

$$A = .163 * \frac{V}{T} \quad (2)$$

where V is the volume of the receiving room and T is the reverberation time in the receiving room, which is defined as the elapsed time for a 60 dB decay in sound pressure level after a sound

source has been shut off. Substitution of Equation (2) into Equation (1) results in an equation which contains an expression that includes the sound pressure level and the absorption in the receiving room. The same expression is used in Reference 10 for establishing the sound power level in this room except for the Waterhouse correction term:

$$C_w = 10 \log \left(1 + \frac{S\lambda}{8V} \right) \quad (3)$$

where λ is the wavelength. This correction term compensates for the increased sound pressure and energy density along the walls relative to the central portion of the room where the sound pressure is measured (Ref. 11). The Waterhouse correction term should be applied to both the receiving and source room. However, since the dimensions of the two rooms are of the same order, and as the distance from microphone to the wall in each of the rooms is approximately the same, the correction applied to the transmission loss will be negligible.

Equation (1) is only applicable above the frequency at which the sound field in the reverberation rooms becomes diffuse. Below this frequency the modal density in the test rooms decreases rapidly with decreasing frequency resulting in large spatial fluctuations in the time averaged sound spectrum. A method that corrects for these spatial sound pressure fluctuations is referred to as the "Plate Reference Method" and is based on the assumption

that a large (1.15 m by 1.46 m), thin (.406 mm) aluminum reference panel behaves according to mass law. The validity of this assumption is determined by the modal density of the test panel and the frequency bandwidth at low frequencies and is limited at higher frequencies by the effect of the critical frequency. The resonance frequency of a thin flat panel, assuming simply supported edge conditions, can be calculated by using (Ref. 12):

$$f_{ss} = \frac{1}{2\pi} \sqrt{\frac{D}{\rho_s}} \left[\left(\frac{m\pi}{a} \right)^2 + \left(\frac{n\pi}{b} \right)^2 \right] \quad (4)$$

where ρ_s is the surface mass of the panel, m and n are the mode numbers, a and b are the plate dimensions and D is the flexural rigidity which is defined by:

$$D = \frac{Et^3}{12(1-\nu^2)} \quad (5)$$

where E is Young's modulus, t is the plate thickness and ν is Poisson's ratio. The critical frequency (Ref. 13) is given by:

$$f_c = \frac{c^2}{2\pi} \sqrt{\frac{\rho_s}{D}} \quad (6)$$

where c is the speed of sound (m/s). The modal density is defined as the number of modes with resonance frequencies in a frequency band of unit width. For frequencies much greater than the fundamental resonance frequency of the panel the modal density of the test panel is given by (Ref. 13):

$$n_d \approx \frac{ab}{2} \sqrt{\frac{\rho_s}{D}} \quad (7)$$

The reference panel exhibits a calculated resonance frequency of 1.2 Hz, a critical frequency of 33,500 Hz and a modal density of 1.334. The one-third octave band with a center frequency of 50 Hz has a bandwidth of 11.5 Hz and thus contains 15 panel resonances, a large enough number to expect mass law behavior. As the 8000 Hz one-third octave band is far below the critical frequency of the test panel (33,500 Hz) the Plate Reference Method is valid for the frequency range of interest (50 Hz - 8000 Hz one-third octave bands) which was established in the introduction. Although a limp, mass loaded, reference panel can be used (like rubber) calibration results in the low frequencies were affected by the shape of this reference panel. The rubber panel bends under its own weight, due to its large dimensions and lack of bending stiffness. This resulted in inconsistent results of the transmission loss measurement of this rubber panel.

The theoretical transmission loss R according to field incidence mass law is given in Reference 14:

$$R = 10 \log \left[\frac{.978 M^2}{\ln \left\{ \frac{1 + M^2}{1 + .043 M^2} \right\}} \right] \quad (8)$$

where the dimensionless mass coefficient is given by $M = \frac{\rho_s \pi f}{\rho c}$ and where ρ is the air density (kg/m^3).

Assuming the aluminum panel has transmission loss characteristics as described by Equation (8) an equivalent absorption area A_{eq} may be defined as:

**Page Missing in
Original Document**

**Page Missing in
Original Document**

test procedure, the fixed test configuration and testing within a continuous time frame aid in achieving the highest possible accuracy.

The addition of treatments to the panel structure on the receiving room side not only affects the transmission loss of the structure but also alters the absorption characteristics of the room. A correction to A_{eq} is needed to account for the use of fiberglass blankets and other highly absorptive porous materials. This can be achieved by applying the treatment to the wall of the receiving room opposite the test panel, thus not changing the transmission loss of the test structure but only the absorption characteristics of the room. As the walls of the receiving room are parallel, a symmetric distribution of the acoustic modes may be assumed and the effect of the sound absorption of the treatment will be the same if applied to the test panel or to the opposite wall. A correction for the absorption of the porous material can then be introduced. As the panel area is only 2.5% of the total wall area of the receiving room, absorption corrections for most other, non-porous, treatments do not affect the transmission loss by more than .5 dB and might be omitted.

COMPARISON OF THE CHARACTERISTICS OF THE TRANSMISSION LOSS APPARATUS WITH ASTM AND ISO STANDARDS

The ASTM Standard (Ref. 8) and the ISO Standards 3741 and

3742 (Refs. 10 and 15) will be used in evaluating the characteristics of the transmission loss apparatus and in establishing a frequency range for which reliable transmission loss data can be obtained if the "Classical Method" approach is used. A comparison with other related literature is included.

Sound Diffusivity

The ASTM Standard Method for determining the noise transmission loss of a test specimen assumes a diffuse sound field in each of the test rooms. To achieve an adequate approximation of a diffuse sound field in each of the rooms it is required that there be a sufficient number of room resonances (normal modes) within a test band, that these normal modes be distributed as uniformly as possible over the band, that the modes have sufficient bandwidth and the directions of propagation corresponding to these modes be distributed as uniformly as possible (Refs. 16, 17 and 18). The recommended minimum frequency to ensure an adequate number of modes in the test room is given by (Ref. 8):

$$f = \left(\frac{4 c^3}{V} \right)^{1/3} \quad (10)$$

where V again is the volume of the room. Applying Equation (10) to both test rooms results in a one-third octave band with a center frequency of at least 160 Hz. According to the ASTM standard the 125 Hz one-third octave band will then provide acceptable results. ISO Standard 3741-1975(E) (Ref. 10) recommends a room volume of 70 m³ for the measurement of sound power levels of broadband noise sources for the 200 Hz one-third octave band. The volume of each of the test rooms is about two-thirds of this recommended volume suggesting a minimum one-third octave test band with a center frequency of 250 Hz. The number of room modes in a frequency band can be calculated from (Ref. 19):

$$\frac{dN}{df} = \frac{4\pi Vf^2}{c^3} + \frac{\pi S_t f}{2c^2} + \frac{L}{8c} \quad (11)$$

where $\frac{dN}{df}$ is the modal density, N is the number of normal room modes, S_t is the surface area of all room walls combined, and L is the total length of the edges. Applying Equation (11) to the dimensions of source and receiving rooms (from Table 2) the approximate number of modes is 21 in the 160 Hz one-third octave band and 36 in the 200 Hz one-third octave band, both of which are sufficient to justify a diffuse field. ISO Standard 3741-1975 (E) (Ref. 10) presents a room qualification procedure for measurement of broad band sound based on the standard deviation of measured sound pressure levels in the test room and is given by:

$$s = (k - 1)^{-1/2} \left[\sum_{i=1}^k (L_i - L_m)^2 \right]^{1/2} \quad (12)$$

TABLE 2. - ACOUSTIC RESONANCE MODES IN SOURCE AND RECEIVING ROOMS

| | | Source Room | | | Receiving Room | | |
|--|-------------------|-------------|-----|------|----------------|-----|------|
| Volume V | [m ³] | 47.1 | | | 43.6 | | |
| Total Wall Area S _t | [m ²] | 78.5 | | | 75.5 | | |
| Total Edge Length L | [m] | 43.4 | | | 42.9 | | |
| One-third octave band center frequency | [Hz] | 160 | 200 | 250 | 160 | 200 | 250 |
| Bandwidth | [Hz] | 37 | 46 | 58 | 37 | 46 | 58 |
| Number of Acoustic Resonances N | [-] | 21 | 37 | 69 | 20 | 35 | 65 |
| Modal Density $\frac{dN}{df}$ | [s] | .57 | .80 | 1.19 | .54 | .76 | 1.12 |

where L_i is the space averaged sound pressure level in dB, L_m is the arithmetic mean of sound pressure levels (dB) and k is the number of source positions. Table 3 presents the computed standard deviation for several one-third octave bands based on measurements in the receiving room.

TABLE 3. - STANDARD DEVIATION OF BROAD BAND SOUND
IN THE RECEIVING ROOM ($k = 25$)

| One-third octave band center frequency [Hz] | Standard deviation [dB] | Maximum allowable standard deviation [dB] |
|--|----------------------------|--|
| 100 | 2.7 | 1.5 |
| 125 | 2.1 | 1.5 |
| 160 | 1.5 | 1.5 |
| 200 | .7 | 1.0 |
| 250 | .6 | 1.0 |
| 315 | .8 | 1.0 |
| 400 | .5 | 1.0 |
| 500 | .3 | 1.0 |
| 630 | .4 | 1.0 |

It is concluded from Table 3 that a diffuse sound field exists for one-third octave bands with a frequency of 200 Hz or higher when the rooms are excited with a random noise source. The 160 Hz one-third octave band gives acceptable results.

Room Dimensions

To ensure a uniform distribution of modes, with respect to frequency and to angle, no two dimensions of either one of the test rooms should be equal or in the ratio of small integers. Table 4 shows the ratios recommended by the ASTM Standard (Ref. 8) and the actual room dimensions of source and receiving rooms.

Also included in this table are the optimum ratios of the room dimensions for which the standard deviation of the real modal frequency distribution with respect to the distribution from Equation (11) is minimum, as calculated by Louden in Reference 20. It is concluded that neither one of the test rooms features optimum dimension ratios, although receiving room dimensions approximate the recommended ratios in the ASTM Standard for the lowest frequency bands.

TABLE 4. - RECOMMENDED AND ACTUAL RATIOS OF ROOM DIMENSIONS

| | | | | | |
|------------------------|---|---|------|---|------|
| ASTM Standard (Ref. 8) | 1 | : | 1.26 | : | 1.59 |
| Louden (Ref. 20) | 1 | : | 1.4 | : | 1.9 |
| Source Room | 1 | : | 1.11 | : | 1.18 |
| Receiving Room | 1 | : | 1.16 | : | 1.54 |

Flanking Transmission

Measurements indicate that transmission loss for sound entering the receiving room via paths other than the test panel is 80 dB or higher for frequencies above 200 Hz (Ref. 21). This implies that for this frequency region noise transmission loss as high as 70 dB can be measured (Ref. 8). In the frequency range from 50 to 200 Hz transmission loss values of 23 to 30 dB have been measured without apparent flanking transmission.

Ambient Noise Levels

Ambient noise levels do not exceed 24 dB in the receiving room and 33 dB in the source room for any one-third octave band with a center frequency greater than 63 Hz. The ASTM Standard (Ref. 8) recommends that measured sound pressure levels, due to signal plus background noise should then exceed 34 dB in the receiving room. Corrections for the background noise should be applied if the levels in the receiving room are between 29 and 34 dB. The adjusted value of the signal level is then given by (Ref. 8):

$$L_s = 10 \log (10^{L_{sb}/10} - 10^{L_b/10}) \quad (13)$$

where L_b is the background noise level, L_{sb} is the combined level of signal and background and L_s is the adjusted signal level.

Room Absorption

In general, room absorption should be as low as possible in order to achieve the best possible simulation of the ideal diffuse field condition and keep the region affected by the direct field of the source as small as possible. Table 5 presents reverberation times measured in the source and receiving rooms along with the average absorption coefficients $\bar{\alpha}$ as calculated from (Ref. 22):

$$\bar{\alpha} = .163 \frac{V}{S_t T} \quad (14)$$

where V is the volume of the room, S_t is the total wall area of the room and T is the reverberation time.

TABLE 5.- REVERBERATION TIMES AND AVERAGE ABSORPTION
COEFFICIENTS IN THE TRANSMISSION LOSS APPARATUS

| One-third octave band center frequency [Hz] | Source Room | | Receiving Room | |
|---|-------------|-----------------------|----------------|-----------------------|
| | T [s] | $\bar{\alpha}$ [-] | T [s] | $\bar{\alpha}$ [-] |
| 125 | 1.45 | .067 | 2.61 | .036 |
| 160 | 1.62 | .061 | 2.86 | .033 |
| 200 | 1.65 | .060 | 2.73 | .034 |
| 250 | 1.70 | .058 | 2.93 | .032 |
| 315 | 1.74 | .056 | 3.00 | .031 |
| 400 | 1.62 | .061 | 2.79 | .034 |
| 500 | 1.58 | .062 | 3.16 | .030 |
| 630 | 1.59 | .062 | 3.43 | .027 |

At frequencies below about 200 Hz the average room absorption coefficient, $\bar{\alpha}$, for each room should be less than (Ref. 8):

$$\bar{\alpha} = \frac{V^{2/3}}{3S_t} \quad (15)$$

which value is .055 for both test rooms. This criterion for room absorption is easily met in the receiving room but not in the source room, as is shown in Table 5. Decreasing the absorption in the source room by 12% will satisfy the ASTM requirements in all one-third octave bands with center frequencies of 160 Hz and higher.

For the lowest test bands, with only few acoustic room modes, a suggested criterion is (Ref. 16):

$$T < 2.2 \frac{dN}{df} \quad (16)$$

where $\frac{dN}{df}$ is the modal density which is defined by Equation (11) and given in Table 2 for the 160 Hz, 200 Hz and 250 Hz one-third octave bands. The criterion of Equation (16) is not met for both test rooms for the one-third octave bands with center frequencies of 250 Hz and lower. For those frequencies increased absorption in the test rooms will broaden modal responses and thus improve modal overlap.

Microphone Location and Distance to Boundaries

The minimum distance from the microphone to the test panel and any of the room boundaries is given by (Ref. 8):

$$d = \frac{c}{2f} \quad (17)$$

which results in a minimum distance of .85 m for the 200 Hz one-third octave band. The actual minimum distance from the microphone, which is mounted at the end of a rotating boom, to any of the room boundaries is .54 m which would satisfy Equation (17) for the 315 Hz and higher one-third octave bands.

The minimum distance from the sound source to the test partition or the nearest measurement point shall be such that the direct field is at least 10 dB below the reverberant field. This is to ensure that the transmission loss results are not biased

significantly by the direct field of the sound source, as the underlying theory involves the interaction of diffuse sound fields and the test partition. Measurements show that this condition is only met for the 200 Hz one-third octave band and lower for the present test configuration. This might be improved by changing the location of the sources and/or microphone boom. For an omnidirectional source mounted on a hard surface, the direct field is 10 dB below the reverberant field at a distance d from the source which is given by (Ref. 8):

$$d = .63 \sqrt{\frac{1}{\bar{\alpha}} S_t} \quad (18)$$

Assuming an average absorption coefficient $\bar{\alpha} = .06$ in the source room, this minimum distance equals 1.43 m. This is almost a factor 1.5 more than the minimum distance in the present test configuration.

Validated Frequency Region

Comparing the characteristics of the test rooms of the Transmission Loss Apparatus with the recommendations in ASTM and ISO standards it is concluded that a random sound field in both test rooms is diffuse in the 250 Hz and higher one-third octave bands provided that the absorption in the source room is decreased by 12%. The 200 Hz one-third octave band might yield acceptable diffusivity, but is not recommended. Table 6 presents a summary of recommended and acceptable minimum one-third octave band center frequencies for which sound diffusivity in both test rooms of the facility is achieved.

TABLE 6. - RECOMMENDED AND ACCEPTABLE MINIMUM FREQUENCIES AT WHICH SOUND DIFFUSITIVITY IS ACHIEVED.

| Criterion | Reference | Minimum one-third octave band frequency [Hz] | |
|--|---------------|--|------------|
| | | Recommended | Acceptable |
| Room volume | ASTM (Ref. 8) | 160 | 125 |
| Room volume | ISO (Ref. 10) | 250 | |
| Number of room modes | | 160 | |
| Sound pressure level standard deviation | ISO (Ref. 10) | 200 | 160 |
| Average absorption coefficient (When absorption in the source room is decreased by 12%) | ASTM (Ref. 8) | 160 | |

In the present configuration the criterion of minimum distance between microphone and room boundaries provides only accurate transmission loss data in the 315 Hz and higher one-third octave bands. Proper location of the microphone booms would enable noise transmission loss measurements in the frequency region where a diffuse field in both test rooms is anticipated (> 250 Hz one-third octave band).

CONCLUDING REMARKS

The layout and present configuration of the NASA Langley Noise Transmission Loss Apparatus has been presented. The test

procedure according to the "Plate Reference Method", currently in use, has been discussed along with a comparison of the characteristics of the test rooms with the criteria and recommendations in ASTM and ISO standards. The Plate Reference Method, based on the assumption that a thin, large aluminum panel exhibits a mass law behavior, is a practical method that not only corrects for spatial sound pressure fluctuations, but also for non-diffusivity close to the room boundaries and in the direct field of the source. The automated procedure and proper temperature control gives reasonable accuracy in the frequency range of interest for identical test configurations. The room dimensions are not critical for executing this method, although higher diffusivity of the test rooms will contribute to a higher accuracy of the test results.

The "Classical Method" is dependent on the diffusivity on the test rooms and therefore is not valid, for the present apparatus configuration. However, if the absorption in the source room is decreased by 12%, which is easily accomplished, this method may be used in one-third octave bands with center frequencies of 200 Hz and higher. To extend the validity of this method to lower frequencies improvements may be obtained by a larger volume of the test rooms, non-parallel walls, rotating diffusers, optimized microphone sweeping area, improved sound absorption at the lowest frequencies and sound source location. Neither of these will result in a great improvement without appreciable design modifications that go beyond the scope of the present apparatus.

From the foregoing discussion the following conclusions can be made.

- Above the 200 Hz one-third octave band two noise transmission loss measurement methods giving the same results are available:
 1. The "Classical Method" according to the ASTM Standard (Ref. 8) which is based on a diffuse sound field in the test rooms.
 2. The "Plate Reference Method" based on the assumption that a large, thin, reference panel follows mass law.
- The Plate Reference Method can also be used in the 50-200 one-third octave bands without any modification to the present apparatus. Along with its ease of application, good accuracy and repeatability, this method is preferred for testing light, propeller driven aircraft type structures for which the frequency of interest is defined from the 50 to the 8000 Hz one-third octave band.
- The Plate Reference Method is valid for only one test set-up and room configuration. A new calibration of the equivalent absorption area is required for any change other than installation of a different test structure.
- A correction to the equivalent absorption area is needed if the surface layer of the test structure facing the receiver room alters the absorption of this room. This correction is estimated currently by applying this layer

to the wall opposite the test structure, thus not changing the transmission loss but only the absorption in the receiving room.

- To minimize the effects of changes in temperature, atmospheric pressure or humidity it is recommended that all noise transmission loss tests be conducted within the same, continuous, time period that is kept as short as possible.

REFERENCES

1. Catherines, J. J. and Mayes, W. H., "Interior Noise Levels of Two Propeller-Driven Light Aircraft", NASA TMX-72716, July 1975.
2. Howlett, J. T. and Morales, D. A., "Prediction of Light Aircraft Interior Noise", NASA TMX-72828, April 1976.
3. Rupf, J. A., "Noise Effects on Passenger Communication in Light Aircraft", SAE Technical Paper 770446, 1977.
4. Wilby, J. F., "Interior Noise of General Aviation Aircraft", SAE Technical Paper 820961, August, 1982.
5. Grosveld, F. M. W. A., "Study of Typical Parameters that Affect Sound Transmission through General Aviation Structures", Doctoral Dissertation, KU-FRL-417-13, Flight Research Laboratory, University of Kansas, Lawrence, Kansas 66045, August 1980.
6. Grosveld, Ferdinand W., "Noise Transmission through Sidewall Treatments Applicable to Twin-Engine Turboprop Aircraft", AIAA Paper 83-0695, April, 1983.
7. Barton, C. K., "Development of a Transmission Loss Test Facility for Light Aircraft Structures", Proceedings of Noise Con 81, Noise Control Foundation, New York, NY, 1981.
8. "ASTM Standard Method for Laboratory Measurement of Airborne Sound Transmission Loss of Building Partitions", American Society for Testing Materials, Designation E90-81, Annual Book of ASTM Standards, Part 18, 1982.


9. Young, R. W., "Sabine Reverberation Equation and Sound Power Calculations", Journal of the Acoustical Society of America, Vol 31, pp. 912-921, 1959.
10. "ISO Acoustics Standard - Determination of Sound Power Levels of Noise Sources - Precision Methods for Broad Band Sources in Reverberation Rooms", ISO 3741-1975(E).
11. Waterhouse, R. V., "Interference Patterns in Reverberation Sound Fields", Journal of the Acoustical Society of America, Vol. 27. No. 2, March, 1955.
12. Leissa, Arthur W., "Vibration of Plates", NASA SP-160, 1969.
13. Ver, Istvan L. and Holmer, Curtis I., "Interaction of Sound Waves with Solid Structures", Noise and Vibration Control, Leo L. Beranek, ed., McGraw-Hill Book Co., c. 1971, pp. 270-361.
14. Mixson, J. S., Roussos, L. A., Barton, C. K., Vaicaitis, R., and Slazak, M., "Laboratory Study of Efficient Add-On Treatments for Interior Noise Control in Light Aircraft", AIAA Paper 81-1969, October, 1981.
15. "ISO Acoustics Standard - Determination of Sound Power Levels of Noise Sources - Precision Methods for Discrete Frequency and Narrow Band Sources in Reverberation Rooms", ISO 3742-1975(E).
16. Lubman, D., "Precision of Reverberant Sound Power Measurements", Journal of the Acoustical Society of America, Vol. 56, No. 2, pp. 523-533, 1974.


17. Bowers, H. D. and Lubman, D., "Decibel Averaging in Reverberant Rooms", Advanced Technology Center, Technical Report 0-71200/8 TR-130, 1968.
18. Maling, G., "Guidelines for the Determination of the Average Sound Power Radiated by Discrete Frequency Sources in a Reverberation Room", Journal of the Acoustical Society of America, Vol. 53, No. 4, pp. 1064-1069, 1973.
19. Morse, P. M., "Vibration and Sound", McGraw-Hill Book Co., New York, 1948.
20. Loudon, M. M., "Dimension Ratios of Rectangular Rooms with Good Distribution of Eigentones", Acustica, 24, 99, 1971.
21. McGary, M. C., "Sound Field Diffusivity in NASA Langley Research Center Hardwalled Acoustic Facilities", NASA TM-83275, March 1982.
22. Larsen, H., "Power Based Measurements of Sound Insulation", Technical Review, No. 3, Bruel and Kjaer, Marlborough, MA, 1980.


APPENDIX A

FLOW CHART OF HP 9845 B

COMPUTER PROGRAM







APPENDIX B

SAMPLE OUTPUT OF COMPUTER PROGRAM FOR TRANSMISSION LOSS MEASUREMENTS

NASA Langley Research Center Transmission Loss Facility

Date: Apr 28 1983 Time: 15.30 EST Run nr: 6 Operator: F.W.GROSVELD

Test panel: COMMANDER


File name: BRMLE

| Center Frequency (Hz) | One-third octave band sound pressure levels (dB) | | | | | | |
|---------------------------------|---|------------------|------|------------------|--------------|--------------|--------|
| | Source room | Receiver room | NR | TL (mass law) | TL (meas) | TL (diff) | |
| 50 | 74.3 | 39.7 | 34.6 | 8.7 | 19.84 | -11.1 | 5148.7 |
| 63 | 74.2 | 47.6 | 26.6 | 10.4 | 9.94 | .4 | 560.0 |
| 80 | 71.6 | 56.7 | 14.9 | 12.1 | 8.27 | 3.8 | 25.4 |
| 100 | 77.0 | 58.3 | 18.7 | 13.9 | 11.10 | 2.8 | 40.1 |
| 125 | 75.4 | 55.3 | 20.1 | 15.8 | 14.55 | 1.2 | 36.0 |
| 160 | 76.5 | 57.5 | 19.0 | 17.7 | 12.59 | 5.1 | 18.0 |
| 200 | 79.3 | 58.6 | 20.7 | 19.7 | 13.94 | 5.7 | 17.0 |
| 250 | 81.3 | 60.2 | 21.1 | 21.6 | 16.45 | 5.2 | 11.9 |
| 315 | 81.8 | 54.0 | 27.8 | 23.6 | 23.69 | -.1 | 35.2 |
| 400 | 82.0 | 49.2 | 32.8 | 25.6 | 28.85 | -3.3 | 70.5 |
| 500 | 82.0 | 44.0 | 38.0 | 27.6 | 35.34 | -7.8 | 147.6 |
| 630 | 83.9 | 42.5 | 41.4 | 29.6 | 39.22 | -9.7 | 204.0 |
| 800 | 87.5 | 44.1 | 43.4 | 31.6 | 41.34 | -9.8 | 204.2 |
| 1000 | 88.0 | 41.9 | 46.1 | 33.6 | 44.84 | -11.3 | 240.0 |
| 1250 | 89.3 | 42.0 | 47.3 | 35.6 | 46.63 | -11.1 | 199.7 |
| 1600 | 88.7 | 39.2 | 49.5 | 37.6 | 48.83 | -11.3 | 209.2 |
| 2000 | 87.7 | 36.0 | 51.7 | 39.6 | 51.12 | -11.6 | 219.0 |
| 2500 | 86.3 | 31.3 | 55.0 | 41.6 | 54.50 | -12.9 | 295.5 |
| 3150 | 84.7 | 26.3 | 58.4 | 43.6 | 57.62 | -14.1 | 407.9 |
| 4000 | 83.4 | 23.5 | 59.9 | 45.6 | 58.81 | -13.3 | 363.6 |
| 5000 | 81.8 | 23.0 | 58.8 | 47.6 | 57.21 | -9.7 | 178.1 |
| 6300 | 79.0 | 21.0 | 58.0 | 49.6 | 55.82 | -6.3 | 93.5 |
| 8000 | 75.1 | 20.0 | 55.1 | 51.6 | 53.62 | -2.1 | 30.2 |
| 10000 | 71.1 | 21.0 | 50.1 | 53.6 | 54.29 | -.7 | 6.0 |
| A-Weighted | 97.5 | 56.3 | 41.2 | | | | |

| | | | | | |
|----------------------------|---------------------|---|----------|--------|---------------------------|
| Test panel properties : | Density | = | 7059 | kg/cum | |
| | Mass per unit area | = | 11.368 | kg/sqm | |
| | Thickness | = | .00161 | m | |
| | Young's modulus | = | 71.0E+09 | N/sqm | |
| | Poisson ratio | = | .33 | | Absorption correction: |
| | Width | = | 1.153 | m | |
| | Length | = | 1.457 | m | |
| | | | | | NC F1 F2 F3 |
| | Resonance frequency | = | 3.0 | Hz | 100 0 0 0 |
| | Critical frequency | = | 13470 | Hz | |

Comment :
TNB on the left side of the panel structure

FC1



Total treatment: 11.30 kg (24.91 lbs) Mass/unit area: 10.38 kg/sm (2.13 psf)

GULFSTREAM COMMANDER 1000 PANEL

| | | | | | | | |
|------|-----|------|-----|------|-----|------|-----|
| A | | B | | C | | D | |
| 1232 | 728 | 1232 | 728 | 1232 | 728 | 1232 | 728 |
| 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| E | | F | | G | | H | |
| 1232 | 728 | 1232 | 728 | 1232 | 728 | 1232 | 728 |
| 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| I | | J | | K | | L | |
| 1232 | 728 | 1232 | 728 | 1232 | 728 | 1232 | 728 |
| 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |

- | | |
|-------------------|--------------|
| 0. Bare skin | .063 inch AL |
| 1. Y-370 | 1.54 kg/sqm |
| 2. Fiberglass | 0.24 kg/sqm |
| 3. Vinyl septum | 1.78 kg/sqm |
| 4. TNB #101 | 4.98 kg/sqm |
| 5. Honeycomb | |
| 6. Trimpanel | 1.27 kg/sqm |
| 7. Vinyl septum 2 | 1.37 kg/sqm |
| 8. Sticky TNB+101 | 4.98 kg/sqm |

Test panel: COMMANDER File name: BRMLE Run nr: 6 Date: April 28 1983 FC1

| | | | | | |
|---|--|-----------------------------|---|--|--|
| 1. Report No. NASA CR-172153 | | 2. Government Accession No. | | 3. Recipient's Catalog No. | |
| 4. Title and Subtitle Characteristics of the Transmission Loss Apparatus at NASA Langley Research Center | | | | 5. Report Date June 1983 | |
| | | | | 6. Performing Organization Code | |
| 7. Author(s) Ferdinand W. Grosveld | | | | 8. Performing Organization Report No. | |
| | | | | 10. Work Unit No. | |
| 9. Performing Organization Name and Address The Bionetics Corporation 20 Research Drive Hampton, VA 23666 | | | | 11. Contract or Grant No. NAS1-16978 | |
| | | | | 13. Type of Report and Period Covered Contractor Report | |
| 12. Sponsoring Agency Name and Address National Aeronautics and Space Administration Washington, DC 20546 | | | | 14. Sponsoring Agency Code | |
| | | | | | |
| 15. Supplementary Notes Langley Technical Monitor: D. G. Stephens | | | | | |
| 16. Abstract A description of the Transmission Loss Apparatus at NASA Langley Research Center, which is specifically designed to accommodate general aviation type aircraft structures, is presented. The measurement methodology, referred to as the "Plate Reference Method", is discussed and compared with the classical method as described in the Standard of the American Society for Testing and Materials. This measurement procedure enables reliable and accurate noise transmission loss measurements down to the 50 Hz one-third octave band. The transmission loss characteristics of add-on acoustical treatments, applied to the basic structure, can be established by inclusion of appropriate absorption corrections for the treatment. | | | | | |
| 17. Key Words (Suggested by Author(s)) Transmission Loss Sound Transmission Noise Measurement Interior Aircraft Noise Acoustic Attenuation | | | 18. Distribution Statement Unclassified - Unlimited Subject Category - 71 | | |
| 19. Security Classif. (of this report) Unclassified | 20. Security Classif. (of this page) Unclassified | 21. No. of Pages 42 | 22. Price* A03 | | |

End of Document